

7. The following Appendix-L shall be inserted, namely :-

APPENDIX-L

FORM 'S'

{See Rule 87 (5)}

Fire Audit Report

Year 2022-23

To,

PRINCIPAL
WEST CENTRAL RAILWAYS SR. SEC. SCHOOL ,
NEW YARD ITARSI DISTRICT HOSHANGABAAD M.P.

Sub: Submission of fire audit report of building Name WEST CENTRAL RAILWAYS SR. SEC. SCHOOL and address NEW YARD ITARSI DISTRICT HOSHANGABAAD M.P.

TOTAL SCHOOL AREA : 28000 SQM

HIGHT OF THE BUILDING : 6.00MTR TO 6.2 MTR

Dear Sir/Madam,

I, VIPIN MISHRA GOVT. APPROVED FIRE CONSULTANT have inspected your building / premises on 1 MARCH 2023 (date) and checked all Fire Equipment's /installations and have completed the Fire Audit of the said Building/Premises WEST CENTRAL RAILWAYS SR. SEC. SCHOOL .

AUDIT PROCESS WILL BE DONE ACCORDING TO NATIONAL BUILDING CODE OF INDIA: 2016 FIRE AND LIFE SAFETY PROVISIONS WHICH COME UNDER PLANNING COMMISSION OF INDIA.

NATIONAL BUILDING CODE OF INDIA ENSURE THAT MINIMUM FIRE FIGHTING LIABILIES A BUILDING SHOULD FOLLOW.

2. Details of fire system installed are as below: -

S. No.	Particular	Available/ Installed or not installed (as per requirements) (give comments)	comments for working of system (attach details, if needed)
1	2	3	4
1.	Access	Available	ACCESS AVAILABLE FROM MULTIPLE SIDE
2.	Wet Riser	NOT APPLICABLE	AS PER THE NATIONAL BUILDING CODE 2016 RULES ACCORDING TO EDUCATIONAL BUILDING
3.	Down Comer	NOT APPLICABLE	ACCORDING TO THE NBC 2016 FIRE AND LIFE SAFETY
4.	Hose Reel	INSTALLED	YES INSTALLED GROUND FLOOR AND FIRST FLOOR
5.	Automatic Sprinkler System	NOT APPLICABLE	AS PER THE RULE OF NBC 2016 FIRE AND LIFE SAFETY BASEMENT NOT AVAILABLE OCCUPANCY COME UNDER THE EDUCATION GROUP
6.	Yard Hydrant	NOT APPLICABLE	AS PER THE RULE OF NBC 2016 FIRE AND LIFE SAFETY

2.

1	2	3	4
7.	Underground Tank with Draw off Connection	NOT APPLICABLE	
8.	Terrace Tanks	Available	2000 LTR AVAILABLE PRESENTLY AS PER THE AREA IT IS SUFFICIENT
9.	Fire Pump	NOT APPLICABLE	
10.	Terrace Pump	INSTALLED	WORKING AS A BOOSTER PUMP FROM TERRACE TO GROUND FLOOR
11.	First Aid Fire Fighting Appliances.	Available	ABC TYPE FIRE EXTINGUISHER CO2 TYPE FIRE EXTINGUISHER AFFF FIRE EXTINGUISHER ARE AVAILABLE IN SUFFICIENT QUANTITY
12.	Pressurization System	NOT APPLICABLE	NOT APPLICABLE BUILDING TOTALLY VENTILATED NO CONFINED AREA NEAR STAIRCASE
13.	Auto Detection System	NOT APPLICABLE	AS PER THE RULE OF NBC 2016 FIRE AND LIFE SAFETY
14.	Manual operated Electrical Fire Alarm System	NOT APPLICABLE	AS PER THE RULE OF NBC 2016 FIRE AND LIFE SAFETY
15.	P.A. System with talk back facility	AVAILABLE	
16.	Emergency Light	INSTALLED	
17.	Auto D.G. Set	NOT APPLICABLE	
18.	Illuminated Exit Sign	AVAILABLE	
19.	Means of Escape	AVAILABLE	MULTIPLE ESCAPE ROUTS AVAILABLE WITH NO OBSTRUCTION
20.	Compartmentation	Available	
21.	MCB/ELCB	INSTALLED	YES, AVAILABLE
22.	Fireman Switch in Lift	NOT APPLICABLE	LIFT IS NOT AVAILABLE

23.	Hose Boxes with Delivery Hose and Branch	NOT APPLICABLE	AS PER THE RULE OF NBC 2016 FIRE AND LIFE SAFETY
24.	Refugee area	Available	AT GROUND FLOOR
25.	any other installation	YES AVAILABLE	SAND BUCKET AVAILABLE

Date : 06/03/2023

V. Mishra
 06/03/2023
VIPIN MISHRA
 Govt. Auth. Fire Consultant
 L.No. 01/BFB/2021

Signature

Name of Fire Engineer: **VIPIN MISHRA**

L. No. : 01/BFB/2021

Add. : 55, PREM NAGAR

CHHOLA BHOPAL M.P.